排ガス測定結果 施設名称 北部清掃工場 測定(採取)位置 煙道測定口

则足(休奴) [四直		度追溯を口 ばいじん* (g/m³N)			塩化水素 * (mg/m³N)			硫黄酸化物 (K値)			窒素酸化物 * (ppm)			ダイオキシン類 * (ng−TEQ/㎡N)			水銀 * (mg/m³N)			
月	測定	結果を得	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉
	年月日 た年月日		法規制値=0.08		0.08	法規制値=700			法規制値=1.17			法規制值=300 250		法規制值=1.0						
	H27.4.16	H27.5.7	0.005未満	_	0.005未満	10	_	9	0.0062	_	0.019	75	_	51	_	_	_	_	_	_
4月																				
	1107 5 00	1107.0.5		0.005 + `#	0.005 + '#		0			0.014			70							
5月	H27.5.22	H27.6.5	_	0.005未満	0.005木満		8	_	_	0.014	_	_	73		_	_	_		_	
	H27.6.17	H27.7.1	0.005未満	_	0.005未満	21	_	7	0.028	_	0.014	72	_	35	_	_	_	_	_	_
6月																				
	H27.7.31	H27.8.21	_	0.005未満	0.005未満		12			0.007		_	56							
7月																				
8月	H27.8.27	H27.9.29	0.005未満	_	0.005未満	31		15	0.0073	_	0.014	74		43	_	_			_	
	H27.8.11	H27.9.9	—	_	—	-	_		—	_	-	_	_	-	_	_	_	0.003	_	
	H27.8.17	H27.9.9	_	_	_	_	_	_	_	_	_	_	_	_	_	_	_	_	0.003未満	
	H27.8.25	H27.9.9	_	_	_	_	_	_	_	_	_	_	_	_	_	_	_	_	_	0.004
	H27.8.11	H27.9.30	_	_	_	_	_	_	_		_	_	_	_	0.00025	_	_	_	_	
	H27.8.17	H27.10.5	_	_	_	_	_	_	_	_	_	_	_	_	_	0.00017	_	_	_	
	H27.8.25	H27.10.13		— 		_	- -+:#	_	_	-	_	_	_	_	_	_	0.0060	_	_	
9月	H27.9.24	H27.12.14	_	0.005未満	0.005木満		5未満	_	_	0.0068	_	_	69		_	_			_	
10月	H27.10.26	H27.12.14	0.005未満	_	0.005未満	9	_	5	0.0076	_	0.0071	73	_	40	_	_	_	_	_	
11月	H27.11.25	H27.12.17	_	0.005未満	0.005未満		5未満	_	_	0.014	_	_	79		_	_	_		_	
]																			
	H27.12.18	H28.1.6	0.005未満	_	_	36		_	0.015	_	_	80	_		_	_			_	
12月		1120.1.0	3.000/N/MJ			- 00			0.010			00								
1月	H28.1.8	H28.1.21	_		0.005未満	_	_	26	_	_	0.080	_	_	39	_	_	_	_	_	_
	H28.1.18	H28.2.9	0.005未満	_	_	13		_	0.028		_	76	_	_	_	_			_	
	110000	1100 0 00			0.00=															
2月	H28.2.2	H28.2.23 H28.3.17	0.005丰港		0.005未満	<u> </u>			— 0.075		_		_			_			_	
	H28.2.15 H28.2.24		0.005木油		0.005未満	<u> </u>		29	0.075 —		0.063	/5 —	_	<u> </u>	_	_			_	
	1120.2.27	1120.0.17			5.5507[八四]			20			0.000			01						
3月																				